

CITY OF MANSFIELD

Legislation Details (With Text)

File #:	21-4	117	Version:	1	Name:	Engineering Services with Plummer Associat to identify possible sites for a future water tre plant.	
Туре:	Res	olution			Status:	Passed	
File created:	6/3/2021				In control:	City Council	
On agenda:	6/14	/2021			Final action:	6/14/2021	
Title:	Resolution - A Resolution Authorizing an Engineering Services Agreement with Plummer Associates, Inc. to Identify Possible Sites for a Future Water Treatment Plant						
Sponsors:	Alex Whiteway						
Indexes:							
Code sections:							
Attachments:	1. Resolution, 2. Mansfield Future Water Treatment Plant Site Selection Plummer Agreement						
Date	Ver.	Action By			Act	on Result	
6/14/2021	1	City Cour	icil		Ар	proved Pass	

Resolution - A Resolution Authorizing an Engineering Services Agreement with Plummer Associates, Inc. to Identify Possible Sites for a Future Water Treatment Plant

The authorization of funds in the amount of sixty-five thousand nine hundred eighteen dollars (\$65,918.00) and approval of a contract with Plummer Associates, Inc. to identify sites for a future water treatment plant.

Staff recommends approval.

The Bud Ervin Water Treatment Plant has a max capacity of 45 million gallons per day (MGD). A final expansion will increase production to 60 MGD. The Water Utilities Department is preparing for the future demand based on the current and projected population growth for the City. Priorities to accomplish this expansion include the acquisition of land which will be the site of the future water treatment plant, as well as the potential for wholesale water supply opportunities. The 2019 Water and Wastewater Master Plan as adopted by the Council has identified the southern portion of Mansfield as the most viable area of town in which to locate the new water treatment plant, as this region is closer to the Integrated Pipeline (IPL) and wholesale customers.

Plummer will consult the City through a scoring of each site based on the following criteria: elevation of property, distance to raw water piping, water distribution connections, sanitary sewer connections, flood plains, soil, and Geotech information. They will also evaluate if a dual power feed will be available.

Utility Operations Fund

Alex Whiteway, Assistant Director, Water Utilities 817-728-3615